

# FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO  
Enterprise Products Operating LLC

AUTHORIZING THE OPERATION OF  
Indian Springs Gas Treating and Processing Plant  
Indian Springs Gas Plant  
Natural Gas Liquid Extraction

LOCATED AT  
Polk County, Texas  
Latitude 30° 45' 24" Longitude 94° 42' 8"  
Regulated Entity Number: RN100228998

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: 03497 Issuance Date: \_\_\_\_\_

\_\_\_\_\_  
For the Commission

## Table of Contents

Section	Page
General Terms and Conditions .....	1
Special Terms and Conditions: .....	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements .....	6
New Source Review Authorization Requirements .....	6
Compliance Requirements.....	7
Risk Management Plan .....	8
Permit Location .....	8
Permit Shield (30 TAC § 122.148) .....	8
Attachments .....	9
Applicable Requirements Summary.....	10
Additional Monitoring Requirements .....	31
Permit Shield .....	33
New Source Review Authorization References .....	37
Appendix A.....	43
Acronym List .....	44

## **General Terms and Conditions**

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

## **Special Terms and Conditions:**

### **Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting**

1. Permit holder shall comply with the following requirements:
  - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
  - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
  - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
  - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.

- E. Emission units subject to 40 CFR Part 63, Subpart ZZZZ as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1090 which incorporates the 40 CFR Part 63 Subpart by reference.
  - F. Emission units subject to 40 CFR Part 63, Subpart HH as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.390 which incorporates the 40 CFR Part 63 Subpart by reference.
  - G. Emission units subject to 40 CFR Part 63, Subpart DDDDD as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1130 which incorporates the 40 CFR Part 63 Subpart by reference.
2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
- A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
  - B. Title 30 TAC § 101.3 (relating to Circumvention)
  - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
  - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
  - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
  - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
  - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
  - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
  - I. Title 30 TAC § 101.222 (relating to Demonstrations)
  - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
- A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
    - (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
    - (ii) Title 30 TAC § 111.111(a)(1)(E)
    - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)

- (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO<sub>x</sub>, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the “Applicable Requirements Summary” attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:
- (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
  - (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
  - (3) Records of all observations shall be maintained.
  - (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer’s eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
  - (5) Compliance Certification:
    - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).

- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from all other sources not specified in 30 TAC § 111.111(a)(1), (4), or (7); the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(8)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(8)(B)(i) or (ii)
- (iii) For a source subject to 30 TAC § 111.111(a)(8)(A), complying with 30 TAC § 111.111(a)(8)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO<sub>x</sub>, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
  - (1) An observation of visible emissions from a source which is required to comply with 30 TAC § 111.111(a)(8)(A) shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter.
  - (2) Records of all observations shall be maintained.
  - (3) Visible emissions observations of sources operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of sources operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each source during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be

evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(4) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A)
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

C. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:

- (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
- (ii) Sources with an effective stack height ( $h_e$ ) less than the standard effective stack height ( $H_e$ ), must reduce the allowable emission level by multiplying it by  $[h_e/H_e]^2$  as required in 30 TAC § 111.151(b)
- (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)

4. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:

- A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
- B. Title 40 CFR § 60.8 (relating to Performance Tests)
- C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
- D. Title 40 CFR § 60.12 (relating to Circumvention)
- E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
- F. Title 40 CFR § 60.14 (relating to Modification)

- G. Title 40 CFR § 60.15 (relating to Reconstruction)
- H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
- 5. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.
- 6. For oil and natural gas production facilities as specified in 40 CFR Part 63, Subpart HH, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.390 incorporated by reference):
  - A. Title 40 CFR § 63.760(a)(1)(i) - (iii) (relating to Applicability and Designation of Affected Source)
  - B. Title 40 CFR § 63.775(d)(9) (relating to Reporting Requirements)

#### **Additional Monitoring Requirements**

- 7. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time or minimum frequency specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

#### **New Source Review Authorization Requirements**

- 8. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule, standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
  - A. Are incorporated by reference into this permit as applicable requirements
  - B. Shall be located with this operating permit
  - C. Are not eligible for a permit shield
- 9. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
- 10. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of



operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).

11. The permit holder shall comply with the following requirements for Air Quality Standard Permits:
  - A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit
  - B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit
  - C. Applicable requirements of 30 TAC § 116.620 for Installation and/or Modification of Oil and Gas Facilities based on the information contained in the registration application.

### **Compliance Requirements**

12. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
13. Use of Discrete Emission Credits to comply with the applicable requirements:
  - A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
    - (i) Title 30 TAC Chapter 115
    - (ii) Title 30 TAC Chapter 117
    - (iii) If applicable, offsets for Title 30 TAC Chapter 116
    - (iv) Temporarily exceed state NSR permit allowables
  - B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
    - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
    - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
    - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)

- (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
- (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

### **Risk Management Plan**

- 14. For processes subject to 40 CFR Part 68 and specified in 40 CFR § 68.10, the permit holder shall comply with the requirements of the Accidental Release Prevention Provisions in 40 CFR Part 68. The permit holder shall submit to the appropriate agency either a compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR § 68.10(a), or as part of the compliance certification submitted under this permit, a certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of a risk management plan.

### **Permit Location**

- 15. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit off site at Enterprise Products, Environmental Department, 1100 Louisiana, Houston, Texas 77002.

### **Permit Shield (30 TAC § 122.148)**

- 16. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

## **Attachments**

**Applicable Requirements Summary**

**Additional Monitoring Requirements**

**Permit Shield**

**New Source Review Authorization References**

### **Applicable Requirements Summary**

<b>Unit Summary .....</b>	<b>11</b>
---------------------------	-----------

<b>Applicable Requirements Summary .....</b>	<b>16</b>
--	-----------

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
FLARE	FLARES	N/A	R1111	30 TAC Chapter 111, Visible Emissions	No changing attributes.
FUG-1	FUGITIVE EMISSION UNITS	N/A	60KKK	40 CFR Part 60, Subpart KKK	No changing attributes.
FUG-2	FUGITIVE EMISSION UNITS	N/A	63HH-001	40 CFR Part 63, Subpart HH	No changing attributes.
GRP-20%	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	H-200, H-305, H-477, H-615A, H-615B, H-716, K-100, K-200, K-300, K-400, K-500, K-501A, K-501B, K-501C, K-600, K-700, K-790A, K-790B, P-214A	R1111	30 TAC Chapter 111, Visible Emissions	No changing attributes.
H-200	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60Dc	40 CFR Part 60, Subpart Dc	No changing attributes.
H-200	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63DDDDDD	40 CFR Part 63, Subpart DDDDD	No changing attributes.
H-305	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63DDDDDD	40 CFR Part 63, Subpart DDDDD	No changing attributes.
H-305	GLYCOL DEHYDRATION	N/A	63HH-1TOX	40 CFR Part 63, Subpart HH	Process Vent Control = BTEX emissions are limited by a control device or a combination of control devices through a closed-vent system., Bypass Device = The closed-vent system contains one or more bypass devices that could be used to divert all or a portion of the

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					gases, vapors, or fumes from entering the control device., Flow Indicator = A flow indicator is installed at the inlet to the bypass device., Unsafe to Inspect = No parts of the closed-vent system are designated as unsafe to inspect., Difficult to Inspect = Parts of the closed-vent system are designated as difficult to inspect, as described in 40 CFR § 63.773(c)(6)(i) - (ii)., Control Device Type = Thermal vapor incinerator., Control Device Operation = The mass content of BTEX in the gases vented to the control device is reduced., Performance Test/Design Analysis Exemption = No performance test/design analysis exemption is being utilized., Performance Test or Design Analysis = Performance test conducted as specified in 40 CFR § 63.772(e)(3)., Sealed Closed Vent System = The closed-vent system contains joints, seams, or other connections that are permanently or semi-permanently sealed.
H-305	GLYCOL DEHYDRATION	N/A	63HH-2FLARE	40 CFR Part 63, Subpart HH	Process Vent Control = BTEX emissions are limited by a control device or a combination of control devices through a closed-vent system., Bypass Device = The closed-vent system contains one or more bypass devices that could be used to divert all or a portion of the

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					gases, vapors, or fumes from entering the control device., Flow Indicator = A flow indicator is installed at the inlet to the bypass device., Unsafe to Inspect = No parts of the closed-vent system are designated as unsafe to inspect., Difficult to Inspect = Parts of the closed-vent system are designated as difficult to inspect, as described in 40 CFR § 63.773(c)(6)(i) - (ii)., Control Device Type = Flare., Sealed Closed Vent System = The closed-vent system contains joints, seams, or other connections that are permanently or semi-permanently sealed.
H-305	GLYCOL DEHYDRATION	N/A	63HH-3BPH	40 CFR Part 63, Subpart HH	Process Vent Control = BTEX emissions are limited by a control device or a combination of control devices through a closed-vent system., Bypass Device = The closed-vent system contains one or more bypass devices that could be used to divert all or a portion of the gases, vapors, or fumes from entering the control device., Flow Indicator = A flow indicator is installed at the inlet to the bypass device., Unsafe to Inspect = No parts of the closed-vent system are designated as unsafe to inspect., Difficult to Inspect = Parts of the closed-vent system are designated as difficult to inspect, as described in

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					40 CFR § 63.773(c)(6)(i) - (ii)., Control Device Type = Boiler or process heater., Control Device Operation = The mass content of BTEX in the gases vented to the control device is reduced., Performance Test/Design Analysis Exemption = No performance test/design analysis exemption is being utilized., Performance Test or Design Analysis = Performance test conducted as specified in 40 CFR § 63.772(e)(3)., Sealed Closed Vent System = The closed-vent system contains joints, seams, or other connections that are permanently or semi-permanently sealed.
H-305	GLYCOL DEHYDRATION	N/A	63HH-4UNCON	40 CFR Part 63, Subpart HH	Process Vent Control = BTEX emissions limit is met through actual uncontrolled operation.
H-477	BOILERS/ STEAM GENERATORS/ STEAM GENERATING UNITS	N/A	63DDDDDD	40 CFR Part 63, Subpart DDDDDD	No changing attributes.
H-615A	BOILERS/ STEAM GENERATORS/ STEAM GENERATING UNITS	N/A	63DDDDDD	40 CFR Part 63, Subpart DDDDDD	No changing attributes.
H-615B	BOILERS/ STEAM GENERATORS/ STEAM GENERATING UNITS	N/A	63DDDDDD	40 CFR Part 63, Subpart DDDDDD	No changing attributes.



### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
H-716	BOILERS/ STEAM GENERATORS/ STEAM GENERATING UNITS	N/A	63DDDDD	40 CFR Part 63, Subpart DDDDD	No changing attributes.
K-600	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
K-700	SRIC ENGINES	N/A	60JJJJ	40 CFR Part 60, Subpart JJJJ	No changing attributes.
K-700	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
K-790A	SRIC ENGINES	N/A	63ZZZZ-B	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
K-790B	SRIC ENGINES	N/A	63ZZZZ-B	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
P-214A	SRIC ENGINES	N/A	63ZZZZ-B	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
VENT-1	GAS SWEETENING/ SULFUR RECOVERY UNITS	N/A	60LLL	40 CFR Part 60, Subpart LLL	No changing attributes.

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FLARE	EU	R1111	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period, except for upset emissions as provided in §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
FUG-1	EU	60KKK	VOC	40 CFR Part 60, Subpart KKK	§ 60.632(a) § 60.482-1(a) § 60.482-1(b) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	Comply with the requirements for compressors as stated in §60.482-3 and §60.482-1(a), (b) and (d), except as provided in §60.633.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) § 60.485(d)(2) § 60.485(d)(3) § 60.485(f) § 60.632(d) [G]§ 60.633(h)	[G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) [G]§ 60.636
FUG-1	EU	60KKK	VOC	40 CFR Part 60, Subpart KKK	§ 60.632(a) § 60.482-1(a) § 60.482-1(b) § 60.482-2(a)(2) § 60.482-2(b)(1) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4)	Comply with the requirements for pumps in light liquid service as stated in §60.482-2 and §60.482-1(a), (b) and (d), except as provided in §60.633.	§ 60.482-2(a)(1) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) § 60.485(d)(2) § 60.485(d)(3) [G]§ 60.485(e) § 60.485(f) § 60.632(d) [G]§ 60.633(h)	[G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) [G]§ 60.636

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k)				
FUG-1	EU	60KKK	VOC	40 CFR Part 60, Subpart KKK	§ 60.632(a) § 60.482-1(a) § 60.482-1(b) § 60.482-4(a) § 60.482-4(b)(1) § 60.482-4(c) § 60.482-4(d)(1) § 60.482-4(d)(2) § 60.482-9(a) § 60.482-9(b) § 60.486(k) [G]§ 60.633(b)(3)	Comply with the requirements for pressure relief devices in gas/vapor service as stated in §60.482-4 and 60.482-1(a), (b) and (d), except as provided in §60.633.	§ 60.482-4(b)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) § 60.485(d)(2) § 60.485(d)(3) § 60.485(f) § 60.632(d) § 60.633(b)(1) § 60.633(b)(2) [G]§ 60.633(b)(3) [G]§ 60.633(b)(4)	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(3) [G]§ 60.486(e)(4) § 60.486(j) [G]§ 60.633(b)(4) [G]§ 60.635(b)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) [G]§ 60.636
FUG-1	EU	60KKK	VOC	40 CFR Part 60, Subpart KKK	§ 60.632(a) § 60.482-1(a) § 60.482-1(b) § 60.482-6(a)(1) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k)	Comply with the requirements for open-ended valves or lines as stated in §60.482-6 and §60.482-1(a), (b) and (d), except as provided in §60.633.	§ 60.485(a) [G]§ 60.485(b) § 60.485(d)(2) § 60.485(d)(3) § 60.485(f) § 60.632(d)	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) [G]§ 60.636

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-1	EU	60KKK	VOC	40 CFR Part 60, Subpart KKK	§ 60.632(a) § 60.482-1(a) § 60.482-1(b) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k)	Comply with the requirements for valves in gas/vapor service as stated in §60.482-7 and §60.482-1(a), (b) and (d), except as provided in §60.633.	§ 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(ii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) § 60.485(d)(2) § 60.485(d)(3) [G]§ 60.485(e) § 60.485(f) § 60.632(d) [G]§ 60.633(h)	[G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) [G]§ 60.636
FUG-1	EU	60KKK	VOC	40 CFR Part 60, Subpart KKK	§ 60.632(a) § 60.482-1(a) § 60.482-1(b) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k)	Comply with the requirements for valves in light liquid service as stated in §60.482-7 and §60.482-1(a), (b) and (d), except as provided in §60.633.	§ 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(ii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) § 60.485(d)(2) § 60.485(d)(3) [G]§ 60.485(e) § 60.485(f) § 60.632(d) [G]§ 60.633(h)	[G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) [G]§ 60.636
FUG-1	EU	60KKK	VOC	40 CFR Part 60, Subpart KKK	§ 60.632(a) § 60.482-1(a) § 60.482-1(b) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b)	Comply with the requirements for pumps in heavy liquid service as stated in §60.482-8, except as provided in §60.633.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) § 60.485(d)(2) § 60.485(d)(3) [G]§ 60.485(e)	[G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) [G]§ 60.636

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k)		§ 60.485(f) § 60.632(d) [G]§ 60.633(h)		
FUG-1	EU	60KKK	VOC	40 CFR Part 60, Subpart KKK	§ 60.632(a) § 60.482-1(a) § 60.482-1(b) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	Comply with the requirements for pressure relief devices in light liquid service as stated in §60.482-8, except as provided in §60.633.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) § 60.485(d)(2) § 60.485(d)(3) [G]§ 60.485(e) § 60.485(f) § 60.632(d) [G]§ 60.633(h)	[G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) [G]§ 60.636
FUG-1	EU	60KKK	VOC	40 CFR Part 60, Subpart KKK	§ 60.632(a) § 60.482-1(a) § 60.482-1(b) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	Comply with the requirements for pressure relief devices in heavy liquid service as stated in §60.482-8, except as provided in §60.633.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) § 60.485(d)(2) § 60.485(d)(3) [G]§ 60.485(e) § 60.485(f) § 60.632(d) [G]§ 60.633(h)	[G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) [G]§ 60.636
FUG-1	EU	60KKK	VOC	40 CFR Part 60, Subpart KKK	§ 60.632(a) § 60.482-1(a) § 60.482-1(b) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	Comply with the requirements for connectors as stated in §60.482-8, except as provided in §60.633.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) § 60.485(d)(2) § 60.485(d)(3) [G]§ 60.485(e)	[G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) [G]§ 60.636

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k)		§ 60.485(f) § 60.632(d) [G]§ 60.633(h)		
FUG-1	EU	60KKK	VOC	40 CFR Part 60, Subpart KKK	§ 60.632(a) § 60.482-1(a) § 60.482-1(b) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k)	Comply with the requirements for valves in heavy liquid service as stated in §60.482-8, except as provided in §60.633.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) § 60.485(d)(2) § 60.485(d)(3) [G]§ 60.485(e) § 60.485(f) § 60.632(d) [G]§ 60.633(h)	[G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) [G]§ 60.636
FUG-2	EU	63HH-001	112(B) HAPS	40 CFR Part 63, Subpart HH	§ 63.769(c) § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10 § 61.242-2(a)(2) [G]§ 61.242-2(b) [G]§ 61.242-2(c) [G]§ 61.242-2(d) [G]§ 61.242-2(e) § 61.242-2(f) § 61.242-2(g) § 63.764(a) § 63.764(j)	Pumps located at nonfractionating plants with a design capacity < 283,000 scm/day, comply with the requirements of §61.242-2 of Subpart V, except as provided in §63.769(c)(5).	[G]§ 61.242-2(d) § 61.242-2(f) [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(h) [G]§ 61.246(i) § 61.246(j) [G]§ 63.774(b)(1) § 63.774(b)(2)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e) § 63.764(b) § 63.775(d) [G]§ 63.775(d)(3) § 63.775(e) § 63.775(e)(1) § 63.775(e)(2)(iv)
FUG-2	EU	63HH-001	112(B) HAPS	40 CFR Part 63, Subpart HH	§ 63.769(c) § 61.242-1(a) § 61.242-1(b)	Valves in gas/vapor or light liquid service located at a nonfractionating plant with a	[G]§ 61.242-7(c) [G]§ 61.242-7(g) [G]§ 61.242-7(h)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.242-1(d) [G]§ 61.242-10 § 61.242-7(b) [G]§ 61.242-7(c) [G]§ 61.242-7(d) [G]§ 61.242-7(e) [G]§ 61.242-7(f) [G]§ 61.242-7(g) [G]§ 61.242-7(h) [G]§ 61.243-1 [G]§ 61.243-2 § 63.764(a) § 63.764(j)	design capacity <283,000 scm/day shall comply with the requirements in §61.242-7(b)-(h) of Subpart V.	[G]§ 61.243-1 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(e) [G]§ 61.246(f) [G]§ 61.246(g) [G]§ 61.246(i) § 61.246(j) [G]§ 63.774(b)(1) § 63.774(b)(2)	§ 61.247(d) [G]§ 61.247(e) § 63.764(b) § 63.775(d) [G]§ 63.775(d)(3) § 63.775(e) § 63.775(e)(1) § 63.775(e)(2)(iv)
GRP-20%	EP	R1111	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
H-200	EU	60Dc	SO <sub>2</sub>	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
H-200	EU	60Dc	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
H-200	EU	60Dc	PM (Opacity)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit	None	§ 60.48c(g)(1) § 60.48c(g)(2)	[G]§ 60.48c(a) § 60.48c(j)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).		§ 60.48c(g)(3) § 60.48c(i)	
H-200	EU	63DDDDDD	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
H-305	EU	63DDDDDD	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
H-305	EU	63HH-1TOX	112(B) HAPS	40 CFR Part 63, Subpart HH	§ 63.765(b)(1)(iii) § 63.764(a) § 63.764(j) § 63.765(b)(1)(iii)(A) § 63.771(c)(1) § 63.771(c)(2) § 63.771(c)(3)(i) § 63.771(c)(3)(ii) § 63.771(f)(1) § 63.771(f)(1)(i) § 63.771(f)(1)(i)(A) § 63.771(f)(2)	The owner or operator must limit BTEX emissions from each existing small glycol dehydration unit process vent, as defined in §63.761, to the limit determined in Equation 1 of this section. The limits determined using Equation 1 must be met in accordance with one of the alternatives specified in paragraphs (b)(1)(iii)(A) through (D) of this section.	§ 63.771(c)(3)(i)(A) [G]§ 63.772(c) § 63.772(d)(1) § 63.772(e) [G]§ 63.772(e)(3) § 63.772(e)(4)(ii) [G]§ 63.772(f) [G]§ 63.773(c)(2)(i) [G]§ 63.773(c)(2)(ii) § 63.773(c)(2)(iv)(A) [G]§ 63.773(d)(1) § 63.773(d)(3) § 63.773(d)(3)(i)(A)	§ 63.771(e)(1) § 63.771(e)(2) § 63.771(e)(3)(i) [G]§ 63.774(b)(1) § 63.774(b)(10) § 63.774(b)(11) § 63.774(b)(2) [G]§ 63.774(b)(3) § 63.774(b)(4) § 63.774(b)(4)(i) § 63.774(b)(4)(ii) § 63.774(b)(4)(iii) § 63.774(b)(4)(iv)	§ 63.764(b) [G]§ 63.773(c)(2)(i) [G]§ 63.773(c)(2)(ii) [G]§ 63.775(b)(1) § 63.775(b)(2) § 63.775(b)(3) § 63.775(b)(4) § 63.775(b)(5) § 63.775(b)(6) § 63.775(d) [G]§ 63.775(d)(1) § 63.775(d)(10) § 63.775(d)(11)



### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.771(f)(2)(i) § 63.771(f)(2)(ii) § 63.773(c)(2)(iv) § 63.773(c)(2)(iv)(A) [G]§ 63.773(c)(3) § 63.773(c)(4) [G]§ 63.773(c)(6)		§ 63.773(d)(3)(ii) § 63.773(d)(3)(iii) § 63.773(d)(4) [G]§ 63.773(d)(5)(i) § 63.773(d)(6) § 63.773(d)(6)(i) § 63.773(d)(6)(ii) § 63.773(d)(6)(iii) § 63.773(d)(6)(iv) § 63.773(d)(6)(v) § 63.773(d)(6)(v)(A) § 63.773(d)(7)	§ 63.774(b)(6) § 63.774(b)(7) § 63.774(b)(7)(i) § 63.774(b)(7)(ii) § 63.774(b)(7)(iii) § 63.774(b)(7)(iv) § 63.774(b)(7)(v) § 63.774(b)(7)(vi) § 63.774(b)(7)(vii) § 63.774(b)(7)(viii) § 63.774(g)	[G]§ 63.775(d)(5) § 63.775(d)(6) § 63.775(d)(7) § 63.775(e) § 63.775(e)(1) § 63.775(e)(2) § 63.775(e)(2)(i) § 63.775(e)(2)(ii) § 63.775(e)(2)(ii)(A) § 63.775(e)(2)(ii)(D) § 63.775(e)(2)(iii) § 63.775(e)(2)(v) [G]§ 63.775(e)(2)(vii) § 63.775(e)(2)(viii) § 63.775(e)(2)(xi) § 63.775(e)(2)(xiv) [G]§ 63.775(f) § 63.775(g)(1)
H-305	EU	63HH-2FLARE	112(B) HAPS	40 CFR Part 63, Subpart HH	§ 63.765(b)(1)(iii) § 63.11(b) § 63.764(a) § 63.764(j) § 63.765(b)(1)(iii)(A) § 63.771(c)(1) § 63.771(c)(2) § 63.771(c)(3)(i) § 63.771(c)(3)(ii) § 63.771(f)(1) § 63.771(f)(1)(iii) § 63.771(f)(2) § 63.771(f)(2)(i) § 63.771(f)(2)(ii) § 63.773(c)(2)(iv) § 63.773(c)(2)(iv)(A) [G]§ 63.773(c)(3) § 63.773(c)(4) [G]§ 63.773(c)(6)	The owner or operator must limit BTEX emissions from each existing small glycol dehydration unit process vent, as defined in §63.761, to the limit determined in Equation 1 of this section. The limits determined using Equation 1 must be met in accordance with one of the alternatives specified in paragraphs (b)(1)(iii)(A) through (D) of this section.	§ 63.771(c)(3)(i)(A) [G]§ 63.772(c) § 63.772(d)(1) § 63.772(e) [G]§ 63.772(e)(2) § 63.772(e)(4)(ii) [G]§ 63.772(f) [G]§ 63.773(c)(2)(i) [G]§ 63.773(c)(2)(ii) § 63.773(c)(2)(iv)(A) [G]§ 63.773(d)(1) § 63.773(d)(3) § 63.773(d)(3)(i)(C) § 63.773(d)(3)(iii) § 63.773(d)(4) § 63.773(d)(6) § 63.773(d)(6)(i) § 63.773(d)(6)(iv) § 63.773(d)(6)(v) § 63.773(d)(6)(v)(A) § 63.773(d)(7)	§ 63.771(e)(1) § 63.771(e)(2) § 63.771(e)(3)(i) [G]§ 63.774(b)(1) § 63.774(b)(10) § 63.774(b)(11) § 63.774(b)(2) [G]§ 63.774(b)(3) § 63.774(b)(4) § 63.774(b)(4)(i) § 63.774(b)(4)(iii)(A) § 63.774(b)(4)(iii) § 63.774(b)(4)(iv) § 63.774(b)(6) § 63.774(b)(7) § 63.774(b)(7)(i) § 63.774(b)(7)(ii) § 63.774(b)(7)(iii) § 63.774(b)(7)(iv) § 63.774(b)(7)(v) § 63.774(b)(7)(vi)	§ 63.764(b) [G]§ 63.773(c)(2)(i) [G]§ 63.773(c)(2)(ii) [G]§ 63.775(b)(1) § 63.775(b)(2) § 63.775(b)(3) § 63.775(b)(4) § 63.775(b)(5) § 63.775(b)(6) § 63.775(d) § 63.775(d)(10) § 63.775(d)(11) [G]§ 63.775(d)(2) § 63.775(d)(6) § 63.775(d)(7) § 63.775(e) § 63.775(e)(1) § 63.775(e)(2) § 63.775(e)(2)(i) § 63.775(e)(2)(ii) § 63.775(e)(2)(ii)(A)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								§ 63.774(b)(7)(vii) § 63.774(b)(7)(viii) § 63.774(g)	§ 63.775(e)(2)(ii)(D) § 63.775(e)(2)(iii) § 63.775(e)(2)(v) [G]§ 63.775(e)(2)(vii) § 63.775(e)(2)(viii) § 63.775(e)(2)(x) § 63.775(e)(2)(xi) § 63.775(e)(2)(xiv) [G]§ 63.775(f) § 63.775(g)(1)
H-305	EU	63HH-3BPH	112(B) HAPS	40 CFR Part 63, Subpart HH	§ 63.765(b)(1)(iii) § 63.764(a) § 63.764(j) § 63.765(b)(1)(iii)(A) § 63.771(c)(1) § 63.771(c)(2) § 63.771(c)(3)(i) § 63.771(c)(3)(ii) § 63.771(f)(1) § 63.771(f)(1)(i) § 63.771(f)(1)(i)(A) § 63.771(f)(2) § 63.771(f)(2)(ii) § 63.771(f)(2)(iii) § 63.773(c)(2)(iv) § 63.773(c)(2)(iv)(A) [G]§ 63.773(c)(3) § 63.773(c)(4) [G]§ 63.773(c)(6)	The owner or operator must limit BTEX emissions from each existing small glycol dehydration unit process vent, as defined in §63.761, to the limit determined in Equation 1 of this section. The limits determined using Equation 1 must be met in accordance with one of the alternatives specified in paragraphs (b)(1)(iii)(A) through (D) of this section.	§ 63.771(c)(3)(i)(A) [G]§ 63.772(c) § 63.772(d)(1) § 63.772(e) [G]§ 63.772(e)(3) § 63.772(e)(4)(ii) [G]§ 63.772(f) [G]§ 63.773(c)(2)(i) [G]§ 63.773(c)(2)(ii) § 63.773(c)(2)(iv)(A) [G]§ 63.773(d)(1) § 63.773(d)(3) § 63.773(d)(3)(i)(D) § 63.773(d)(3)(ii) § 63.773(d)(3)(iii) § 63.773(d)(4) [G]§ 63.773(d)(5)(i) § 63.773(d)(6) § 63.773(d)(6)(i) § 63.773(d)(6)(ii) § 63.773(d)(6)(iii) § 63.773(d)(6)(iv) § 63.773(d)(6)(v) § 63.773(d)(6)(v)(A) § 63.773(d)(7)	§ 63.771(e)(1) § 63.771(e)(2) § 63.771(e)(3)(i) [G]§ 63.774(b)(1) § 63.774(b)(10) § 63.774(b)(11) § 63.774(b)(2) [G]§ 63.774(b)(3) § 63.774(b)(4) § 63.774(b)(4)(i) § 63.774(b)(4)(ii) § 63.774(b)(4)(iii) § 63.774(b)(4)(iv) § 63.774(b)(6) § 63.774(b)(7) § 63.774(b)(7)(i) § 63.774(b)(7)(ii) § 63.774(b)(7)(iii) § 63.774(b)(7)(iv) § 63.774(b)(7)(v) § 63.774(b)(7)(vi) § 63.774(b)(7)(vii) § 63.774(b)(7)(viii) § 63.774(g)	§ 63.764(b) [G]§ 63.773(c)(2)(i) [G]§ 63.773(c)(2)(ii) [G]§ 63.775(b)(1) § 63.775(b)(2) § 63.775(b)(3) § 63.775(b)(4) § 63.775(b)(5) § 63.775(b)(6) § 63.775(d) § 63.775(d)(10) § 63.775(d)(11) § 63.775(d)(6) § 63.775(d)(7) § 63.775(e) § 63.775(e)(1) § 63.775(e)(2)(iii) § 63.775(e)(2)(v) § 63.775(e)(2)(xi) § 63.775(e)(2)(xiv) [G]§ 63.775(f) § 63.775(g)(1)
H-305	EU	63HH-4UNCON	112(B) HAPS	40 CFR Part 63, Subpart HH	§ 63.765(b)(1)(iii) § 63.764(a) § 63.764(j)	The owner or operator must limit BTEX emissions from each existing small glycol	[G]§ 63.772(b)(2) [G]§ 63.772(d)(2)	§ 63.771(e)(1) § 63.771(e)(3)(i) [G]§ 63.774(b)(1)	§ 63.764(b) [G]§ 63.775(b)(1) § 63.775(b)(2)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.765(b)(1)(iii)(D)	dehydration unit process vent, as defined in §63.761, to the limit determined in Equation 1 of this section. The limits determined using Equation 1 must be met in accordance with one of the alternatives specified in paragraphs (b)(1)(iii)(A) through (D) of this section.		§ 63.774(b)(10) § 63.774(b)(11) § 63.774(b)(2) § 63.774(g)	§ 63.775(b)(3) § 63.775(b)(4) § 63.775(b)(5) § 63.775(b)(6) § 63.775(d) § 63.775(d)(10) § 63.775(d)(7) § 63.775(e) § 63.775(e)(1) § 63.775(e)(2)(xi) [G]§ 63.775(f)
H-477	EU	63DDDDD	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
H-615A	EU	63DDDDD	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
H-615B	EU	63DDDDD	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					requirements of 40 CFR Part 63, Subpart DDDDD				
H-716	EU	63DDDDDD	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
K-600	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.2 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i)	For each existing non-emergency, non-black start stationary CI RICE with a site rating less than 100 HP, located at a major source, you must comply with the requirements as specified in Table 2c.2.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii	§ 63.6625(i) § 63.6655(d) § 63.6655(e) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
K-700	EU	60JJJJ	CO	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table1 § 60.4234 § 60.4243(b) § 60.4243(b)(1) [G]§ 60.4243(d) § 60.4243(g) § 60.4246	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than or equal to 100 HP and less than 130 HP and were manufactured on or after 01/01/2009 must comply with a CO emission limit of 387 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4237(c)	§ 60.4243(a)(1) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(3) § 60.4245(b)	[G]§ 60.4245(e)
K-700	EU	60JJJJ	HC and NO <sub>x</sub>	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table1 § 60.4234 § 60.4243(b) § 60.4243(b)(1)	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than or equal to 100 HP and less than 130	§ 60.4237(c)	§ 60.4243(a)(1) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(3) § 60.4245(b)	[G]§ 60.4245(e)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4243(d) § 60.4243(g) § 60.4246	HP and were manufactured on or after 01/01/2009 must comply with an HC+NO <sub>x</sub> emission limit of 10 g/HP-hr, as listed in Table 1 to this subpart.			
K-700	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
K-790A	EU	63ZZZZ-B	Formaldehyde	40 CFR Part 63, Subpart ZZZZ	§ 63.6600(a)-Table1a.1.a § 63.6595(c) § 63.6600(a)-Table1b.1.a § 63.6600(a)-Table1b.1.b § 63.6605(a) § 63.6605(b) § 63.6625(h) § 63.6630(a) § 63.6640(b)	For each 4SRB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, except during periods of startup, operating at 100% load plus or minus 10%, you must reduce formaldehyde emissions by 76% or more.	§ 63.6610(a) § 63.6610(b) § 63.6610(c) [G]§ 63.6610(d) § 63.6615 § 63.6620(a) § 63.6620(a)-Table4.2.a.i § 63.6620(a)-Table4.2.a.ii § 63.6620(a)-Table4.2.a.iii § 63.6620(a)-Table4.2.a.iv § 63.6620(b) § 63.6620(b)(1)	§ 63.6620(i) § 63.6630(a)-Table5.7.a.iii § 63.6635(a) § 63.6635(c) § 63.6655(a) § 63.6655(a)(1) § 63.6655(a)(2) § 63.6655(a)(3) § 63.6655(a)(4) § 63.6655(a)(5) [G]§ 63.6655(b) § 63.6655(d) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6620(i) § 63.6630(c) § 63.6640(b) § 63.6640(e) § 63.6645(a) § 63.6645(g) § 63.6645(h) § 63.6645(h)(2) § 63.6650(a) § 63.6650(a)-Table7.1.a.i § 63.6650(a)-Table7.1.b § 63.6650(a)-Table7.1.c § 63.6650(b) § 63.6650(b)(1) § 63.6650(b)(2) § 63.6650(b)(3)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.6620(d) § 63.6620(e)(1) [G]§ 63.6625(b) § 63.6630(a)-Table5.7.a.i § 63.6630(a)-Table5.7.a.ii § 63.6630(a)-Table5.7.a.iii § 63.6635(a) § 63.6635(b) § 63.6640(a) § 63.6640(a)-Table6.4.a.i § 63.6640(a)-Table6.4.a.ii § 63.6640(a)-Table6.4.a.iii § 63.6640(a)-Table6.4.a.iv § 63.6640(b)		§ 63.6650(b)(4) [G]§ 63.6650(c) [G]§ 63.6650(e) § 63.6650(f)
K-790B	EU	63ZZZZ-B	Formaldehyde	40 CFR Part 63, Subpart ZZZZ	§ 63.6600(a)-Table1a.1.a § 63.6595(c) § 63.6600(a)-Table1b.1.a § 63.6600(a)-Table1b.1.b § 63.6605(a) § 63.6605(b) § 63.6625(h) § 63.6630(a) § 63.6640(b)	For each 4SRB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, except during periods of startup, operating at 100% load plus or minus 10%, you must reduce formaldehyde emissions by 76% or more.	§ 63.6610(a) § 63.6610(b) § 63.6610(c) [G]§ 63.6610(d) § 63.6615 § 63.6620(a) § 63.6620(a)-Table4.2.a.i § 63.6620(a)-Table4.2.a.ii § 63.6620(a)-Table4.2.a.iii § 63.6620(a)-Table4.2.a.iv § 63.6620(b) § 63.6620(b)(1) § 63.6620(d) § 63.6620(e)(1)	§ 63.6620(i) § 63.6630(a)-Table5.7.a.iii § 63.6635(a) § 63.6635(c) § 63.6655(a) § 63.6655(a)(1) § 63.6655(a)(2) § 63.6655(a)(3) § 63.6655(a)(4) § 63.6655(a)(5) [G]§ 63.6655(b) § 63.6655(d) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6620(i) § 63.6630(c) § 63.6640(b) § 63.6640(e) § 63.6645(a) § 63.6645(g) § 63.6645(h) § 63.6645(h)(2) § 63.6650(a) § 63.6650(a)-Table7.1.a.i § 63.6650(a)-Table7.1.b § 63.6650(a)-Table7.1.c § 63.6650(b) § 63.6650(b)(1) § 63.6650(b)(2) § 63.6650(b)(3) § 63.6650(b)(4) [G]§ 63.6650(c)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.6625(b) § 63.6630(a)-Table5.7.a.i § 63.6630(a)-Table5.7.a.ii § 63.6630(a)-Table5.7.a.iii § 63.6635(a) § 63.6635(b) § 63.6640(a) § 63.6640(a)-Table6.4.a.i § 63.6640(a)-Table6.4.a.ii § 63.6640(a)-Table6.4.a.iii § 63.6640(a)-Table6.4.a.iv § 63.6640(b)		[G]§ 63.6650(e) § 63.6650(f)
P-214A	EU	63ZZZZ-B	Formaldehyde	40 CFR Part 63, Subpart ZZZZ	§ 63.6600(a)-Table1a.1.a § 63.6595(c) § 63.6600(a)-Table1b.1.a § 63.6600(a)-Table1b.1.b § 63.6605(a) § 63.6605(b) § 63.6625(h) § 63.6630(a) § 63.6640(b)	For each 4SRB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, except during periods of startup, operating at 100% load plus or minus 10%, you must reduce formaldehyde emissions by 76% or more.	§ 63.6610(a) § 63.6610(b) § 63.6610(c) [G]§ 63.6610(d) § 63.6615 § 63.6620(a) § 63.6620(a)-Table4.2.a.i § 63.6620(a)-Table4.2.a.ii § 63.6620(a)-Table4.2.a.iii § 63.6620(a)-Table4.2.a.iv § 63.6620(b) § 63.6620(b)(1) § 63.6620(d) § 63.6620(e)(1) [G]§ 63.6625(b) § 63.6630(a)-	§ 63.6620(i) § 63.6630(a)-Table5.7.a.iii § 63.6635(a) § 63.6635(c) § 63.6655(a) § 63.6655(a)(1) § 63.6655(a)(2) § 63.6655(a)(3) § 63.6655(a)(4) § 63.6655(a)(5) [G]§ 63.6655(b) § 63.6655(d) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6620(i) § 63.6630(c) § 63.6640(b) § 63.6640(e) § 63.6645(a) § 63.6645(g) § 63.6645(h) § 63.6645(h)(2) § 63.6650(a) § 63.6650(a)-Table7.1.a.i § 63.6650(a)-Table7.1.b § 63.6650(a)-Table7.1.c § 63.6650(b) § 63.6650(b)(1) § 63.6650(b)(2) § 63.6650(b)(3) § 63.6650(b)(4) [G]§ 63.6650(c) [G]§ 63.6650(e) § 63.6650(f)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							Table5.7.a.i § 63.6630(a)- Table5.7.a.ii § 63.6630(a)- Table5.7.a.iii § 63.6635(a) § 63.6635(b) § 63.6640(a)- § 63.6640(a)- Table6.4.a.i § 63.6640(a)- Table6.4.a.ii § 63.6640(a)- Table6.4.a.iii § 63.6640(a)- Table6.4.a.iv § 63.6640(b)		
VENT-1	PRO	60LLL	SO <sub>2</sub>	40 CFR Part 60, Subpart LLL	§ 60.640(b)	Facilities that have a design capacity less than 2 LT/D of H <sub>2</sub> S in the acid gas (expressed as sulfur) are required to comply with §60.647(c) but not §60.642 through §60.646.	None	§ 60.647(c)	None



**Additional Monitoring Requirements**

**Periodic Monitoring Summary ..... 32**

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-20%	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: If alt. fuel is fired for > 24 consecutive hours, report as a deviation or conduct Test Method 22. If visible emissions are observed using Test Method 22, report as a deviation or conduct Test Method 9. If opacity > 20%, report as a deviation.	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, for a period greater than or equal to 24 consecutive hours it shall be considered and reported as a deviation or the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are observed. Any time an alternate fuel is fired for a period of greater than 7 consecutive days then visible emissions observations will be conducted no less than once per week. Documentation of all observations shall be maintained. If visible emissions are present during the firing of an alternate fuel, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

**Permit Shield**

**Permit Shield ..... 34**

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
FLARE	N/A	40 CFR Part 60, Subpart A	The flare is not used to satisfy a regulatory requirement in any NSPS and NESHAP.
FLARE	N/A	40 CFR Part 63, Subpart A	The flare is not used to satisfy a regulatory requirement in any MACT.
GRP-WWATER	TK-780A, TK-780B, TK-780C, TK-780D	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
H-305	N/A	40 CFR Part 60, Subpart Dc	Unit has a maximum design heat input capacity less than 2.9 MW (10 MMBtu/hr).
H-477	N/A	40 CFR Part 60, Subpart Dc	Unit has a maximum design heat input capacity less than 2.9 MW (10 MMBtu/hr).
H-615A	N/A	40 CFR Part 60, Subpart Dc	Unit has a maximum design heat input capacity less than 2.9 MW (10 MMBtu/hr).
H-615B	N/A	40 CFR Part 60, Subpart Dc	Unit has a maximum design heat input capacity less than 2.9 MW (10 MMBtu/hr).
H-716	N/A	40 CFR Part 60, Subpart Dc	Unit has a maximum design heat input capacity less than 2.9 MW (10 MMBtu/hr).
K-100	N/A	40 CFR Part 63, Subpart ZZZZ	Engine is an existing spark ignition 4SLB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.
K-200	N/A	40 CFR Part 63, Subpart ZZZZ	Engine is an existing spark ignition 4SLB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.
K-300	N/A	40 CFR Part 63, Subpart ZZZZ	Engine is an existing spark ignition 4SLB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.
K-400	N/A	40 CFR Part 63, Subpart ZZZZ	Engine is an existing spark ignition 4SLB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.
K-500	N/A	40 CFR Part 63, Subpart ZZZZ	Engine is an existing spark ignition 4SLB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.
K-501A	N/A	40 CFR Part 63, Subpart ZZZZ	Engine is an existing spark ignition 4SLB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.
K-501B	N/A	40 CFR Part 63, Subpart ZZZZ	Engine is an existing spark ignition 4SLB stationary RICE with a site rating of

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
			more than 500 brake HP located at a major source of HAP emissions.
K-501C	N/A	40 CFR Part 63, Subpart ZZZZ	Engine is an existing spark ignition 4SLB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.
LOAD	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	In Polk County all loading and unloading of VOC other than gasoline (to or from transport vessels) is exempt from the requirements of this division.
PLOAD	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	In Polk County all loading and unloading of VOC other than gasoline (to or from transport vessels) is exempt from the requirements of this division.
PTSWASHER	N/A	40 CFR Part 63, Subpart T	The parts washer does not use a halogenated solvent.
T-906	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
TK-226	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
TK-772	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
TK-773	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
TK-774A	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
TK-774B	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
TK-907	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
TK-912	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
TK-913	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
TK-914	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
TK-915	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
TK-916	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
TK-917	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
TK-918	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
TK-919	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
V-101	N/A	40 CFR Part 60, Subpart Kb	Tank is a pressure tank.
VENT-1	N/A	30 TAC Chapter 112, Sulfur Compounds	Facility is not a sulfur recovery plant.

**New Source Review Authorization References**

<b>New Source Review Authorization References .....</b>	<b>38</b>
<b>New Source Review Authorization References by Emission Unit .....</b>	<b>39</b>

### New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 80400	Issuance Date: 11/07/2017
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 106.359	Version No./Date: 09/10/2013
Number: 106.454	Version No./Date: 11/01/2001
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.473	Version No./Date: 09/04/2000
Number: 106.476	Version No./Date: 09/04/2000



### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
FLARE	BACKUP FLARE	80400
FUG-1	FUGITIVES	80400
FUG-2	FUGITIVE COMPONENTS UNDER MACT HH	80400
H-200	HOT OIL HEATER (60 MMBTU/HR)	80400
H-200	HOT OIL HEATER (VENT)	80400
H-305	GLYCOL 1 REBOILER HEATER H-305	80400
H-305	GLYCOL 1 REBOILER HEATER H-305 (VENT)	80400
H-477	CRYOGENICS 1 HEATER (4.0 MMBTU/HR)	80400
H-477	CRYOGENICS 1 HEATER (VENT)	80400
H-615A	AMINE REBOILER HEATER H-615A	80400
H-615A	AMINE REBOILER HEATER H-615A (VENT)	80400
H-615B	AMINE REBOILER HEATER H-615B	80400
H-615B	AMINE REBOILER HEATER H-615B (VENT)	80400
H-716	CRYOGENICS 2 REGENERATOR (2.0 MMBTU/HR)	80400
H-716	CRYOGENICS 2 REGENERATOR (VENT)	80400
K-100	1340-HP COMPRESSOR - K-100	80400
K-100	1340-HP COMPRESSOR - K-100 (VENT)	80400
K-200	1340-HP COMPRESSOR - K-200	80400
K-200	1340-HP COMPRESSOR - K-200 (VENT)	80400
K-300	1340-HP COMPRESSOR - K-300	80400
K-300	1340-HP COMPRESSOR - K-300 (VENT)	80400

### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
K-400	1340-HP COMPRESSOR - K-400	80400
K-400	1340-HP COMPRESSOR - K-400 (VENT)	80400
K-500	1970-HP COMPRESSOR - K-500	80400
K-500	1970-HP COMPRESSOR - K-500 (VENT)	80400
K-501A	3335-HP COMPRESSOR - K-501A	80400
K-501A	3335-HP COMPRESSOR - K-501A (VENT)	80400
K-501B	3335-HP COMPRESSOR - K-501B	80400
K-501B	3335-HP COMPRESSOR - K-501B (VENT)	80400
K-501C	2225-HP COMPRESSOR - K-501C	80400
K-501C	2225-HP COMPRESSOR - K-501C (VENT)	80400
K-600	DIESEL AIR COMPRESSOR ENGINE	80400
K-600	DIESEL AIR COMPRESSOR ENGINE (VENT)	80400
K-700	EMERGENCY GENERATOR ENGINE	80400
K-700	EMERGENCY GENERATOR ENGINE (VENT)	80400
K-790A	1478-HP COMPRESSOR - K-790A	80400
K-790A	1478-HP COMPRESSOR - K-790A (VENT)	80400
K-790B	1478-HP COMPRESSOR - K-790B	80400
K-790B	1478-HP COMPRESSOR - K-790B (VENT)	80400
LOAD	TRUCK LOADING	80400
P-214A	736-HP AMINE PUMP ENGINE - P-214A	80400
P-214A	736-HP AMINE PUMP ENGINE - P-214A (VENT)	80400

### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
PLOAD	PRESSURIZED TRUCK LOADING	80400
PTSWASHER	REMOTE RESERVOIR COLD SOLVENT CLEANER	106.454/11/01/2001
T-906	SLOP TANK (400 BBL) TK-906	80400
TK-226	AMINE TANK (658 GAL)	80400
TK-772	GASOLINE TANK (3,000 GAL)	106.473/09/04/2000
TK-773	LUBE OIL TANK (3,000 GAL)	80400
TK-774A	ANTIFREEZE TANK (1,000 GAL)	80400
TK-774B	ANTIFREEZE TANK (1,000 GAL)	80400
TK-780A	WASTEWATER TANK (210 BBL)	80400
TK-780B	WASTEWATER TANK (210 BBL)	80400
TK-780C	WASTEWATER TANK (210 BBL)	80400
TK-780D	WASTEWATER TANK (210 BBL)	80400
TK-907	BTEX CONDENSER LIQUIDS TANK (400 BBL) TK-907	80400
TK-912	LUBE OIL TANK (140 BBL)	80400
TK-913	ANTIFREEZE TANK (1,000 GAL)	80400
TK-914	AMINE TANK (1,000 GAL)	80400
TK-915	GLYCOL TANK (1,000)	80400
TK-916	METHANOL TANK (1,000 GAL)	80400
TK-917	GASOLINE TANK (550 GAL)	106.472/09/04/2000
TK-918	DIESEL TANK (250 GAL)	80400
TK-919	CS-1 TANK (1,000 GAL)	80400

### **New Source Review Authorization References by Emissions Unit**

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

<b>Unit/Group/Process ID No.</b>	<b>Emission Unit Name/Description</b>	<b>New Source Review Authorization</b>
V-101	CONDENSATE TANK (714 BBL)	106.476/09/04/2000
VENT-1	AMINE ACID GAS VENT #1	80400

**Appendix A**

**Acronym List ..... 44**

## Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H <sub>2</sub> S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO <sub>x</sub>	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
SIP	state implementation plan
SO <sub>2</sub>	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound